




BORE WELL AND TANK



WASTEWATER RECYCLING



WATER DISTRIBUTION SYSTEM





BACTERIOLOGY REPORT

Lab No.: W-22118/22119/22120/22122/24

Sample Received Date: 04/11/2024

- 1) Water Sample From PNP Hostel Tank JNMC Belagavi.
- 2) Water Sample From Dental Hospital JNMC Belagavi
- 3) Water Sample From KLE Hospital JNMC Belagavi.
- 4) Water Sample From A/14 Quaters Under Ground Tank JNMC

Test Performed : Macro broth dilution technique using Mac Conkey's Broth.

Observation : Colour - Not Changed
Turbidity - Not Present

Remarks : E.Coli Or Other Thermotolerent Coliforms Are **NOT** Found In 100ml Of Water Sample Tested.

Report : The Water sample tested is **FIT** for human consumption.

Date: 06/11/2024

I/C Dr. Jyoti .M. Nagamoti

Dr. Sheetal Harakuni
HOD Microbiology

Copy to: 1) The Director Administration KLE Hostels & residential Quarters JNMC Belagavi.

2) The Principal, JNMC, Belagavi

3) The Hostel Warden, JNMC, Belagavi



BACTERIOLOGY REPORT

Lab No.: W-21426/21428/21430/21432/21434/21436/24

Sample received: 100ml Water samples from.

- 1) Water Sample From Nursing Hostel JNMC Tank JNMC.
- 2) Water Sample From PNP Hostel Tank JNMC Belagavi.
- 3) Water Sample From Dental Hospital JNMC Belagavi
- 4) Water Sample From GLSR Fillter House JNMC Belagavi.
- 5) Water Sample From KLE Hospital JNMC Belagavi.
- 6) Water Sample From A/14 Quaters Under Ground Tank JNMC

Test Performed : Macro broth dilution technique using Mac Conkey's Broth.

Observation : Colour - Not Changed
Turbidity - Not Present

Remarks : E.Coli Or Other Thermotolerent Coliforms Are **NOT** Found In 100ml Of Water Sample Tested.

Report : The Water sample tested is FIT for human consumption.

Date: 23/10/2024

I/C Dr. M.B. Nagamoti

Dr. Sheetal Harakuni
HOD Microbiology

Copy to: 1) The Director Administration KLE Hostels & residential Quarters JNMC Belagavi.

2) The Principal, JNMC, Belagavi

3) The Hostel Warden, JNMC, Belagavi



EHSRDC ENVIRONMENTAL HEALTH AND SAFETY
RESEARCH & DEVELOPMENT CENTRE LLP
P 080 23012100
M 76194 76407

E : ehsrdc2010@gmail.com
ehsrdc2010@ehsrdc.in
W : www.ehsrdc.in

EHSRDC ENVIRONMENTAL HEALTH AND SAFETY RESEARCH AND DEVELOPMENT CENTRE LLP

(Recognised under section 12 of the Environment (Protection) Act, 1986) New Delhi.

ಇವಚ್ ಎಸ್ ಆರ್ ಡಿ ಸಿ ಎನ್ವಿರಾನ್ಮೆಂಟ್ ಹೆಲ್ತ್ ಅಂಡ್ ಸೇಫ್ಟಿ ರಿಸರ್ಚ್ ಅಂಡ್ ಡೆವಲಪ್ ಮೆಂಟ್ ಸೆಂಟರ್ ಎಲ್ ಎಲ್ ಪಿ

(ಪರಿಸರ (ಸಂರಕ್ಷಣೆ) ಕಾಯ್ದೆ, 1986 ರ ಕಲಂ 12 ರಲ್ಲಿ ಮಾನ್ಯತೆ ಪಡೆದ ಪ್ರಯೋಗಾಲಯ) ನವ ದೆಹಲಿ.

ಐಐಇಇಆರ್ ಡಿ ಸಿ ಏನ್ವಾಯರ್ಮೆಂಟ್ ಹೆಲ್ತ್ ಅಂಡ್ ಸೇಫ್ಟಿ ರಿಸರ್ಚ್ ಅಂಡ್ ಡೆವಲಪ್ ಮೆಂಟ್ ಸೆಂಟರ್ ಎಲ್ ಎಲ್ ಪಿ

(पर्यावरण (संरक्षण) अधिनियम, 1986 अनुभाग 12 की धारा मान्यता प्राप्त प्रयोगशाला) न्यु दिल्ली.



TC-13845

Office Address : No.13/2, 1st Main Road, Near Fire Station, Industrial Town, Rajajinagar, Bangalore - 560 010.

ಕಛೇರಿ ವಿಳಾಸ : ನಂ. 13/2, 1ನೇ ಮುಖ್ಯರಸ್ತೆ, ಅಗ್ನಿಶಾಮಕ ಕಛೇರಿ ಹತ್ತಿರ, ಇಂಡಸ್ಟ್ರಿಯಲ್ ಟೌನ್, ರಾಜಾಜಿನಗರ, ಬೆಂಗಳೂರು - 560 010

ISO 9001 : 2015, ISO 14001 : 2015 & ISO 45001 : 2018, ISO / IEC 17025 : 2017 Accredited Testing Laboratory by NABL

Test Report

EHSRDC / GEN / F / 29 / 01 / 00

ANALYSIS REPORT OF WASTE WATER QUALITY

1. Name of the Project : JNMC KLE University Campus, Nehru Nagar, Belagavi, Karnataka 590010.
2. Sample Collected by : Brought by customer
3. Date of Collection : 15.10.2024
4. Particulars of Sample Collected : STP Treated Water
5. Date of Sample Receipt : 16.10.2024
6. Sample Number : EHSRDC/KLE/WW/24/10/12168
7. Analysis started on : 16.10.2024
8. Analysis Completed on : 19.10.2024
9. Report Issued on : 19.10.2024
10. Page No. : 1 of 1
11. Protocol : APHA, 24th Edition/ IS Standard.
12. ULR No : TC1384524000012168F

Sl. No	Parameters	Test Method	Unit	Result	Tolerance Limit (KSPCB Norms)
1.	pH	IS 3025 Part 11	--	7.57	6.5-9.0
2.	Oil & Grease	APHA 5520 B	mg/L	BDL	Not Specified
3.	B.O.D (3 days @ 27°C)	IS 3025 Part 58	mg/L	13	<30
4.	Chemical Oxygen Demand	IS 3025 Part 34	mg/L	40	<250
5.	Total Nitrogen	APHA 4500- N B	mg/L	4.75	<10
6.	Ammonical Nitrogen	IS 3025 Part 44	mg/L	1.12	<5
7.	Total Suspended Solids	IS 3025 Part 17	mg/L	5	<20

Note: BOD: Biochemical Oxygen Demand.

INFERENCE

As per Tolerance Limit (KSPCB Norms), the measured values for the above parameters are within the standards.

End of Report

Supriya S.
Analysed by

[Signature]
Verified by

[Signature]
Nethravathi L
(Authorized Signatory)

Concern towards protecting Environment

Note:

1. The results refer only to the tested samples & applicable parameters.
2. Sample(S) not drawn by us unless stated.
3. Total liability of our laboratory is to invoiced amount. Any dispute arising out of this report is subjected to Bangalore jurisdiction only.
4. The Report Shall not be reproduced partially without the consent of the laboratory.
5. After 15 days of report submission the samples will be discarded.
6. Complaint register is available at the laboratory at the reception.



EHSRD ENVIRONMENTAL HEALTH AND SAFETY
RESEARCH & DEVELOPMENT CENTRE LLP

P 080 23012100
M 76194 76407

E : ehsrdc2010@gmail.com
ehsrdc2010@ehsrdc.in
W : www.ehsrdc.in

EHSRD ENVIRONMENTAL HEALTH AND SAFETY RESEARCH AND DEVELOPMENT CENTRE LLP

(Recognised under section 12 of the Environment (Protection) Act, 1986) New Delhi.

ಇವಿಚ್‌ಆರ್‌ಡಿ&ಡಿ ಎನ್ವಿರಾನ್‌ಮೆಂಟಲ್ ಹೆಲ್ತ್ ಅಂಡ್ ಸೇಫ್ಟಿ ರಿಸರ್ಚ್ ಅಂಡ್ ಡೆವಲಪ್‌ಮೆಂಟ್ ಸೆಂಟರ್ ಎಲ್‌ಎಲ್‌ಪಿ

(ಪರಿಸರ (ಸಂರಕ್ಷಣಾ) ಕಾಯ್ದೆ, 1986 ರ ಕಲಂ 12 ರಲ್ಲಿ ಮಾನ್ಯತೆ ಪಡೆದ ಪ್ರಯೋಗಾಲಯ) ನವ ದೆಹಲಿ.

ಐಐಇಸಿಆರ್‌ಡಿಐಸಿ ಎನ್‌ವಾಯರ್ಮೆಂಟಲ್ ಹೆಲ್ತ್ ಅಂಡ್ ಸೇಫ್ಟಿ ರಿಸರ್ಚ್ ಅಂಡ್ ಡೆವಲಪ್‌ಮೆಂಟ್ ಸೆಂಟರ್ ಎಲ್‌ಎಲ್‌ಪಿ

(पर्यावरण (संरक्षण) अधिनियम, 1986 अनुभाग 12 की धारा मान्यता प्राप्त प्रयोगशाला) न्यू दिल्ली.



TC-13845

Office Address : No.13/2, 1st Main Road, Near Fire Station, Industrial Town, Rajajinagar, Bangalore - 560 010.

ಕಛೇರಿ ವಿಳಾಸ : ನಂ. 13/2, 1ನೇ ಮುಖ್ಯರಸ್ತೆ, ಅಗ್ನಿಶಾಮಕ ಕಛೇರಿ ಹತ್ತಿರ, ಇಂಡಸ್ಟ್ರಿಯಲ್ ಟೌನ್, ರಾಜಾಜಿನಗರ, ಬೆಂಗಳೂರು - 560 010

ISO 9001 : 2015, ISO 14001 : 2015 & ISO 45001 : 2018, ISO / IEC 17025 : 2017 Accredited Testing Laboratory by NABL

Test Report

EHSRD / GEN / F / 29 / 01 / 00

ANALYSIS REPORT OF WASTE WATER QUALITY

- | | |
|------------------------------------|------------------------------------------------------------------------------|
| 1. Name of the Project | : JNMC KLE University Campus,
Nehru Nagar, Belagavi,
Karnataka 590010. |
| 2. Sample Collected by | : Brought by customer |
| 3. Date of Collection | : 15.10.2024 |
| 4. Particulars of Sample Collected | : STP Treated Water, Grab Sampling |
| 5. Date of Sample Receipt | : 16.10.2024 |
| 6. Sample Number | : EHSRD/KLE/WW/24/10/12168 |
| 7. Analysis started on | : 16.10.2024 |
| 8. Analysis Completed on | : 19.10.2024 |
| 9. Report Issued on | : 19.10.2024 |
| 10. Page No. | : 1 of 1 |
| 11. Protocol | : APHA, 24 th Edition/ IS Standard. |
| 12. ULR No | : TC1384524000012168F |

Sl. No	Parameters	Test Method	Unit	Result	Tolerance Limit (KSPCB Norms)
1.	Fecal Coliform	APHA 9221 E	MPN Index /100ml	47	<100

INFERENCE

As per Tolerance Limit (KSPCB Norms), the measured value for the above parameter is within the standards.

End of Report

Analysed by

Verified by

Basavaraj K M
(Authorized Signatory)

Concern towards protecting Environment

Note:

- The results refer only to the tested samples & applicable parameters.
- Sample(S) not drawn by us unless stated.
- Total liability of our laboratory is to invoiced amount. Any dispute arising out of this report is subjected to Bangalore jurisdiction only.
- The Report Shall not be reproduced partially without the consent of the laboratory.
- After 15 days of report submission the samples will be discarded.
- Complaint register is available at the laboratory at the reception.

Eco Care Engineering and Services

Office: Shop No 2 Ansurakar Galli Belgaum
Ph no:7795725626

Service Report


Client Name	THE PRINCIPAL JNMC BELGAUM TEACHING HOSPITAL, NEHRU NAGAR	Report No.	09
City	BELGAUM	Date	05/11/2024
Contact Person	Yadhav sir	Telephone No.	-
Mobile	9901505258	Under Guarantee/Warranty	Yes/No <input checked="" type="checkbox"/>
Address:	Nahru Nagar . Belagavi		

Type of Service Installation Commissioning Troubleshootig Maintenance AnyOther _____

Type of Plant : WTP STP ETP RO _____

Sr.No	Activities Carried Out
1	Nature of Problem Reported Plant Running Good condition
2	Nature of Problem Observed Same as above
3	Details of service work carried out we checked plant and motors
4	Result after servicing working is good condition
5	Spare parts replaced -
6	Customer remarks -

Date	From	To
------	------	----

Site Engineer	Client	Apporval Authority
Name: Umesh	THE PRINCIPAL JNMC BELGAUM TEACHING HOSPITAL, NEHRU NAGAR, BELGAUM	Name:
Date: 05/11/2024	Date:	Date :
		Sign :